

TIM-2000-5 Installation Instructions

Warning regarding Pulse Meter Connections

When making connections to the pulse meter, a wrench must be placed on the adapters to prevent them from being driven into the meter body. The body of the pulse meter is aluminum and will crack if excessive torque is applied. The adapters are tightened prior to shipment and require no further adjustment.

Connecting steel tubing to both connectors can result in cracked meters due to thermal expansion, vibration, et cetera. Recommended: attach rubber hose to one or both connectors.

Meter is bidirectional.

